

September 30, 2002

THE CLOROX COMPANY
TECHNICAL CENTER
JIM MCCABE
7200 JOHNSON DRIVE
PLEASANTON CA 94588-8004

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE
Manufacturer: THE CLOROX COMPANY
Product Name: LIQUID PLUMBER SEPTIC SYSTEM TREATMENT
Model Number(s): NONE
Product File No: 20020315

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2007.

This approval is contingent upon compliance with the following stipulation(s):

- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.

This approval supersedes the approval issued on INSERT DATE under product file number 19970297.

Based on information supplied by the manufacturer and reviewed by the department, this approval recognizes that this plumbing product will not adversely affect bacterial action in the private sewage system, soil hydraulic conductivity in the absorption areas, or groundwater quality beneath the system when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

THE CLOROX COMPANY

Page 2

September 30, 2002

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 Phone
(608) 267-9566 Fax
gschlueter@commerce.state.wi.us Email

GWS:gws